



AFFILIATE CODE: F619701
CERTIFICATE NO.: IN-GZ-5305-190016E

Date: September 2, 2019

Certificate of Conformity

Product Name : Air-cooled Chiller(Heat Pump)

Model(s) : RCMA 18AN, RCMA 24AN, RCMA 30AN, RCMA 40AN, RCMA 50AN, RCMA 60AN, RCMA 75AN, RCMA 90AN, RCMA 100AN, RHMA 18AN, RHMA 24AN, RHMA 30AN, RHMA 40AN, RHMA 50AN, RHMA 60AN, RHMA 75AN, RHMA 90AN, RHMA 100AN

Applicant : York Guangzhou Air Conditioning & Refrigeration Co., Ltd.

Address of Applicant : Xuetian, Longshan Town, Fogang County, Guangdong PC:511685 P.R. China

TCF Number : IN-GZ-5305-190016E

Applicable Standards : EN 61000-6-2:2005, EN 61000-6-4:2007+A1:2011

Declaration : In the Opinion of SGS the Submitted Technical File IN-GZ-5305-190016E Satisfies the Requirements of the Electromagnetic Compatibility Directive 2014/30/EU Annex-I.

Conclusion

Based upon a review of the worksheet and the Technical Construction File, the apparatus is deemed to meet the requirements of the above standards and hence fulfils the requirements of:

Electromagnetic Compatibility Directive 2014/30/EU

Note: This certificate is only valid for the equipment and configuration described and in conjunction with the technical data detailed above.

The CE mark as shown below can be used under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives.



FOR AND ON BEHALF OF SGS-CSTC
STANDARDS TECHNICAL SERVICES CO., LTD.


AUTHORIZED SIGNATURE

Certifier
On Date September 2, 2019

The member of (SGS Group) Société Générale de Surveillance

SGS-CSTC Standards Technical Services Co., Ltd.
16/F, Century YuHui Mansion, No. 73, Fucheng Road, Beijing China
Tel: (86-10) 6845 6699
Fax: (86-10) 6845 7979

This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf. The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

SGSPAPER
19763297



SGS Portugal, S.A.
Industrial Services
Pólo Tecnológico de Lisboa
R. Cupertino de Miranda, Lt 6, Piso 0 e 1
1600-546 Lisboa - Portugal
T. (351) 21 710 42 00
F. (351) 21 715 75 26



EU Final Assessment and Manufacturing Conformity
According to Directive 2014/68/EU



Certificate N°: **PTC19.06633.5120**

Date: **2019.09.20**

Name and Address
of the Manufacturer:

**YORK Guangzhou Air Conditioning and Refrigeration
Co.,Ltd
Xuetian Longshan Town Fogang County Guangdong
PC: 511685
P.R. China**

SGS Portugal SA as a notified body for the scope of Pressure Equipment Directive 2014/68/EU, certifies that the Pressure Equipment design, construction and inspection, is in compliance with the requirements of the Pressure Equipment Directive stated, according module A2.

Certificate of Conformity



Assessed According to
Directive 2014/68/EU:

Module A2

Inspection Report N°: **PTR19.07659.5120**

Equipment ID:

**Air-cooled Chiller (Heat Pump) ; Model: RHMA
100AN ; Variants: RCMA 18AN/RHMA 18AN/RCMA
24AN/RHMA 24AN/RCMA 30AN/RHMA 30AN/RCMA
40AN/RHMA 40AN/RCMA 50AN/RHMA 50AN/RCMA
60AN/RHMA 60AN/RCMA 75AN /RHMA 75AN/RCMA
90AN/RHMA 90AN/RCMA 100AN/RHMA 100AN ;**

PED Data:

**PS [bar]: 45/29.5 (High side / Low side)
TS [°C]: -29/117 (High side); -20/60 (Low side)
Category: II
Fluid/Group: Gas / Gr. 2
PT [bar]: 50.5 / 32.2 Date: 2019.04.10
(High side / Low side)
Year of Manufacture: 2019**

Valid Until: **2020.02.19**



**Carlos Felgueiras
Technical Responsible**



SGS-IP-496/1 (2019-07-01)

John